

STORMWATER MANAGEMENT

410-887-3768

August 7, 2020

KCI
936 Ridgebrook Road
Sparks, MD 21152
Attn: John Blondell, P.E.

RE: Jennifer Branch Relief Sewer
Stormwater Management Variance
Lower Gunpowder Falls Watershed
Project I.D. M190297
Tracking Number: 05-20-3283

Dear Mr. Blondell;

This office has reviewed the information submitted and finds that a stormwater management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. Section 33-4-113 (a) (2) allows a stormwater management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of the design standards would result in unreasonable hardship or practical difficulty and not fulfill the intent of the regulations.

This project is for the installation of sanitary sewer main and manholes by cut and cover. The existing cover conditions will be re-established once project is completed. Although the disturbed area is in excess of 5,000 square feet, there will be no increase in impervious area or runoff resulting from the project.

Please contact Jeannette Applauso, PE, at 410-887-3768 should you have any questions.

Very truly yours,

/signed/

Kritty Udhin, P.E., Manager
Stormwater Management
Department of Environmental Protection
& Sustainability

KU:jcm